



Karnataka State Fire And Emergency Services Department

Office of the District fire officer
Karnataka state fire and Emergency Services
Raichur Fire Station, Raichur-584102.



C.NO: 82/FSR/DFO/RCR/2026

Date:30/04/2026

"Fire Safety Recommendation"

ANNEXURE-I

Group-B Educational Building

"B1 And B2- Schools Up to Senior Secondary Level and other institutions"
NBC-2016, Part-4, Table 7 (11) 3. 1. 3 Group-B Educational Buildings

To,
The Head Master
Vidya Jyoti Higher Primary and High School, Gabbur.
Tq-Devadurga Dist-Raichur.

Sir/Madam,

Sub:- Issue of "Fire Safety Recommendation" to Vidya Jyoti Education Development Trust ® Gabbur. Constructed a Low Rise School Building Vidya Jyoti Higher Primary and High School, Gabbur. Taluk-Devadurga, Dist-Raichur.

Ref :- 1).C.No:21/INS/FSO/DEVADURGA/2026, Date:29/04/2026
2).Applicant Request Letter on Dated: 21/04/2026.

With reference to the subject above cited, the Premises Vidya Jyoti Education Development Trust ® Gabbur. Constructed a Low Rise School Building Vidya Jyoti Higher Primary and High School, Gabbur. Taluk-Devadurga, Dist-Raichur. was inspected by FSO Devadurga on Dated:-22/04/2026 with respect to fire Prevention, fire fighting and evacuation measures to be complied premises and Submitted building details as under.

A. Details of the Building/Premises:-

01	Name and Address of the applicant.	:	The Head Master Vidya Jyoti Higher Primary and High School, Gabbur. Tq-Devadurga Dist-Raichur.
02.	Name and Address of the premises.	:	Vidya Jyoti Higher Primary and High School, Gabbur. Tq-Devadurga Dist-Raichur.
03.	Name and Address of the Building owner.	:	The President Vidya Jyoti Education Development Trust ® Gabbur. Tq-Devadurga Dist-Raichur
04.	Number of Buildings	:	01 No.
05.	Number of floor	:	Ground Floor+02 Upper Floor
06	Floor-wise details of occupancy :-		
	Ground Floor	:	Class Rooms-04 No's,
	First Floor	:	Room-06 No's, Bath Rooms.
	Second Floor	:	Room-06 No's, Bath Rooms.

Page 1 of 4

SECRETARY

Vidyajyothi Education Development Trust (R)
GABBUR-584 113.
Tq. Devadurga. Dist. Raichur



PRINCIPAL
VIDYAJYOTI HIGHER PRIMARY
AND HIGH SCHOOL
GABBUR-584113.
Tq. Devadurga, Dist. Raichur
Disse Code : 29060104009

07	Height of the building	:	12.50 Mtrs.	
08	Site area	:	1776.77. Sq.Mtrs.	
09	Built-up area of each floor :-			
10	Ground Floor	:	312.15 Sq.Mtrs.	
	First Floor	:	312.15 Sq.Mtrs.	
	Second Floor	:	312.15 Sq.Mtrs.	
	Total built-up area	:	936.45 Sq.Mtrs.	
11	Surrounding properties:-			
	East (Side)	:	Siddeshwara Temple	
	West (Side)	:	Residential Houses.	
	North (Rear)	:	Service Road	
	South (Front)	:	Open Plot	
12.	Set back area available around the Building:-			
	East (Side)	:	02.00 Mtrs	Recommended To provide: as per The Allowed Setback Shall be Kept from and Obstruction Further Construction Local Zonal Regulations.
	West (Side)	:	02.00 Mtrs	
	North (Rear)	:	25.00 Mtrs	
	South (Front)	:	00.00 Mtrs	

B. On inspection of this Institutional premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl.No [01]	Details [02]	Existing [03]		Recommendations [04]
01.	Accessibility to Premises.	The premises are accessible from 04.00 Mtrs. Service Road Connecting to South Side of the School and the Road is hardened to carry the weight of 45,000 kgs.		Adequate.
02.	No of entrances.	01 No. Width 5.00 Mtrs.		-----
03.	No. of staircases available	No of staircase	: 01 No.	-----
		Width of staircase	: 01.30 Mtrs.	
		Width of treads	: 30 CM	
		Height of risers	: 15 CM	
		No of riser per flight	: 25 No's	
		Height of handrails	: 1.10 Mtrs	
		Head room clearance	: --	
04.	Portable Fire Extinguisher	1).04 Kg Capacity of 04 No's ABC Type fire Extinguisher Provided. 2).4.5 KG Capacity of 02 No's CO2 Fire Extinguisher Provided.		<u>Recommended to Provided :-</u> Extinguishers as below mentioned 1).One ABC Type fire extinguisher each of 6 kg capacity For Every 100 m2. 2).One CO2 Fire Extinguisher of 4.5

			kg Capacity shall be Provided near electrical Panel Board. [All the extinguishers suggested above should be with B.I. S markings and should be located at an easily accessible position without obstructing the normal passage and maintained periodically].
05.	Escape routes	Not Marked.	Recommended To Provide Direction in which the students have to move in the event of an emergency should be displayed in the corridor in each floor during evacuation.
06.	First aid Hose reel hose.	Provided One Hose reel Hose required for every 1000 m2 of built up area and GI Pipe of minimum 63 mm shall be provided Hose Reel Hose of minimum 19 mm Size of adequate Length to reach the farthest point should be provided near the staircase at each floor with a shut off Branch having a Nozzle of 5 mm Size.	Complied With
07.	At the terrace tank level with minimum pressure of 3.5 kg/cm2.	Provided 01 No of 05 HP Capacity Pump.	Complied With
08.	Terrace tank Over Respective Tower Terrace	Provided 3000 Liters Capacity terrace Tank.	Recommended to Provided :- Terrace tank (RCC of FRP/under Ground tank of 5000 Liters Capacity required with 450 LPM Booster pump, All the Fire Fighting pumps shall be Connected to alternative power supply (DG of Suitable Capacity).
09.	Diesel Generators	Provided 15 KV Diesel Generator It should be connected to alternate power supply in case failure of Electricity.	Complied With
10.	Fire order (Fire Safety Plans)	Not Displayed	Recommended To Provide The Notice board have been indicted the action should be taken by the employees in case of any emergency should be displayed with the telephone number of Devadurga Fire Station i.e-08531-260101 and the telephone number of nearest Ambulance services and Police Station.
11.	No Smoking Board	Displayed As per sec-4 of COPTA a board with words NO SMOKING AREA shall be written in English & Kannada both language shall be prominently displayed at inside the entry /exit of the each floor.	Complied With
12.	Fire Siren	Provided A Fire Siren shall installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.	Complied With

13.	Nominate one Fire Nodal Officer	Not yet Nominated	Recommended To Provide A fire nodal officer shall be nominated either from teaching or non teaching staff.
14.	Nominate Fire Fighting Training	Not Imparted	Recommended To Provide At-least 40% of School Staff should be got trained in basic fire fighting at R.A. Mundkur fire & Emergency Services Academy, Bannerughatta road, Bangalore within 3 months or at an early date
15.	Fire Precautionary Measures:- A. Explosive and Flammable Materials Should Not be Stored in the Store Room, UPS Room Electrical Panel Area, Class Rooms, Laboratory And Electrical Some Panel Premises. B. Accumulation of combustible Waste in and around the premises should be avoided. C. The Exit Ways Shall be always Kept Clear Without any obstruction. D. Liquefied Petroleum Gas Should Not be Stored in the building. E. The doors shall not kept Locked/ Latched during working hours and shall be free from obstruction. F. During the class hours in the class room doors shall not be locked from inside to outside. G. As per Honorable Supreme Court Order All Teachers and staffs Shall be trained to handle Safety Equipment, initiate Emergency Evacuation and Protect Their Students in the event of Fire and other Emergency and the school shall observe the Fire Safety Day on April 14 th of Every Year by Conducting Fire Safety Drills with Co-ordinate with fire service Department.		


Under the Circumstance stated above, there is No Objection to run Education activities in **Vidya Jyoti Education Development Trust @ Gabbur**. Constructed a Low Rise School Building **Vidya Jyoti Higher Primary and High School, Gabbur, Taluk-Devadurga, Dist-Raichur**. School Building subject to the Condition of providing Additional Fire Fighting Equipments and Fire precautionary measures shown in Part-B. Therefore management should compulsory Karnataka Fire And Emergency Services Department conditions to provide Additional Equipments And Then Intimate to the office Within 90 days Positively Without Fail. **This Fire Safety Recommendation Certificate Valid for Only One Year From The date of issue and renewable without fail**.

U-DISE Code:- 29060104009.

To.

- 1).The DGP KSF&ES
Bangalore.
- 2).Fire Station Officer
Fire Station Devadurga

Your's faithfully


ಪ್ರಾಥಮಿಕ ಶಾಲಾ ಅಧ್ಯಾಪಕರು
ವಿಜಯ ಜ್ಯೋತಿ ಹೈಯರ್ ಪ್ರಿಮರಿ
ಗಾಬ್ಬುರ-584113
ರಾಯಚೂರು-584102

